



Manufacturers of  
Quality Storage  
Tank Equipment  
Since 1898

## BULLETIN 4-22-08

### Clarification on pressure / vapor capacity of the components of the NO. 20 TANK GAUGE

The following components have been pressure tested and are 100% inspected to be pressure and vapor tight at 5 PSI:

Reading Section    Part # 20R-20GX

Lower Housing/  
Proving Device    Part # 20R-20A

Elbows                Part # 20R-20H

Float                  Part # 12-AF

Tokheim gauges are also fully enclosed and tamper proof.

560 31st Street  
Marion, Iowa 52302

(319) 362-4847  
Fax (319) 362-4229