



Manufacturers of
Quality Storage
Tank Equipment
Since 1898

BULLETIN 4-22-08

Clarification on pressure / vapor capacity of the components of the NO. 20 TANK GAUGE

The following components have been pressure tested and are 100% inspected to be pressure and vapor tight at 5 PSI:

Reading Section Part # 20R-20GX

Lower Housing/
Proving Device Part # 20R-20A

Elbows Part # 20R-20H

Float Part # 12-AF

Tokheim gauges are also fully enclosed and tamper proof.

560 31st Street
Marion, Iowa 52302

(319) 362-4847
Fax (319) 362-4229